



## State of Utah

GARY R. HERBERT  
Governor

SPENCER J. COX  
Lieutenant Governor

## Department of Environmental Quality

Amanda Smith  
Executive Director

DIVISION OF WATER QUALITY  
Walter L. Baker, P.E.  
Director

May 29, 2015

### DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE TO REISSUE A UPDES PERMIT

#### **PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

#### **PERMIT INFORMATION**

PERMITTEE NAME:	Bear River City Corporation
MAILING ADDRESS:	P.O. Box 160, Bear River City, UT 84301-0160
TELEPHONE NUMBER:	435-279-9047
FACILITY LOCATION:	Northwest of Ogden in Box Elder County
UPDES PERMIT NO.:	UT0020311
PERMITTED OUTFALLS	001
RECEIVING WATER:	Malad River then Bear River

#### **BACKGROUND**

Bear River City Corporation UPDES permit has Discharge, Biosolids and Storm Water Components. The City lagoon system was put into operation in 1974 to treat residential sewage for the City. The design flow of the treatment facility is 0.36 million gallons per day. The treatment facility consists of a pump station, a pressurized 6 inch line, followed by a six cell facultative lagoon system that has a total containment capacity of 54.4 acre feet, with a surface area of 10.4 acres. The primary cell was designed for 156 pounds of BOD<sub>5</sub> per day with a population equivalent of 916 people.

#### **PUBLIC COMMENTS**

Public comments are invited any time prior to the deadline of the close of business on June 29, 2015. Written public comments can be submitted to: Ken Hoffman, UPDES Engineering Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [kenhoffman@utah.gov](mailto:kenhoffman@utah.gov). After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

The permit is available for public review under "Public Notices" at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Ken Hoffman at 801-536-4313.